

Certificate of Analysis



TEST HOUSE LIMITED

An ISO 9001:2008 Certified Organisation

SP-2, 22 Godown Industrial Estate, JAIPUR 302 006 Rajasthan, India

Phone: 91 141 2210057, 2211254, 2211417 Fax: 2212411

e-mail: oasisjaipur@gmail.com, oasusers@gmail.com


AR. No. : M210802001

CIN:U85195RJ1986PLC003527

Manufacturer/ Party	MAHESWARI PUBLIC SCHOOL JAWAHAR NAGAR, JAIPUR				
C/O	N.S.				
Sample	RO WATER				
Reference no. of letter	N.S.	Date	23/07/2021	Received on	02/08/2021
Batch No.	N.S.	Batch size	N.S.	Lic. No.	N.S.
Sample Qty.	2Ltr.	Mfg. date	N.S.	Exp. date	N.S.
Original manufacturer	N.S.				
Supplier's Name	N.S.				
Result of test/analysis					

TEST	RESULT	SPECIFICATION
Chemical Analysis: =====		As per IS: 10500-2012 of Drinking water. Limits
Description	: Clear colourless liquid	
pH	: 8.02	6.5 - 8.5
Total dissolve solids	: 540.000 mg/Lit.	500.0 mg/Lit. Max.
Total hardness as CaCO ₃	: 360.958 mg/Lit.	200.0 mg/Lit. ,,
Calcium as Ca	: 90.750 mg/Lit.	75.0 mg/Lit. ,,
Magnesium as Mg	: 32.604 mg/Lit.	30.0 mg/Lit. ,,
Chloride as Cl	: 90.357 mg/Lit.	250.0 mg/Lit. ,,
Sulphate as SO ₄	: 64.185 mg/Lit.	200.0 mg/Lit. ,,
Nitrate as NO ₃	: 19.059 mg/Lit.	45.00 mg/Lit. ,,
Iron as Fe	: 0.079 mg/Lit.	0.3 mg/Lit. ,,
Fluoride as F	: 0.200 mg/Lit.	1.0 mg/Lit. ,,
Total Alkalinity as CaCO ₃	: 268.107 mg/Lit.	200.0 mg/Lit. ,,
Microbiological Examination =====		As per IS 1622:1981
Escherichia coli	: Absent/100ml	Shall not be detectable in any 100ml sample
Coliform	: Present/100ml	Shall not be detectable in any 100ml sample

←----- End of Report ----->


ASHOK VAID
Principal
Maheshwari Public School
Jawahar Nagar, Jaipur

Note:- Party asked for above test only

Date : 10/08/2021

Microbiologist


Person-in-Charge of testing

Note : 1. The opinion is with respect to the test(s) carried out and mentioned above. 2. The results listed refer only to the sample (as provided by the party) and tested for applicable parameters, on the date of analysis endorsement of products is neither inferred nor implied. 3. Total liability of our company is limited to the invoiced amount. 4. The certificate of analysis is not to be reproduced-wholly or in part and can not be used as an evidence in the Court of Law and should not be used in any advertising media without our special permission in writing. 5. The jurisdiction for any legal case shall be limited to competent courts at Jaipur only.



Mahalaxmi Services

Certification of Cleaning of Water Storage Tanks

Name of Client : Maheshwari Public School

Description : Cleaning and Disinfection of water storage tank through Mechanized dewatering, Sludge Removal, High Pressure cleaning, Vacuum Cleaning, Anti-bacterial spray and U.V. Radiation.

Address of Project : Jawahar Nagar, Jaipur


Date of Work Completion : 28/7/2021

This Statement is to certify that the work of mechanically cleaning the water storage tanks for the above project have been carried out and completed in accordance with the NATIONAL POLICY ON SAFETY, HEALTH AND ENVIRONMENT AT WORK PLACE.

Certify by



Mukesh Bhadani
Managing Director


ASHOK VAID
Principal
Maheshwari Public School
Jawahar Nagar, Jaipur

Contact Us:

367, Vasundhara Colony, Tonk Road, Jaipur – 302018
Ph: +91 97834 70077 | E-mail: services.mahalaxmi2020@gmail.com